

See discussions, stats, and author profiles for this publication at: <https://www.researchgate.net/publication/344928962>

# Hybrid Power System for a Fuel Station Considering Temperature Coefficient

Article in *International Journal of Energy Economics and Policy* · September 2020

DOI: 10.32479/ijeep.9886

CITATIONS

0

READS

23

3 authors, including:



**Damilola Elizabeth Babatunde**

Covenant University Ota Ogun State, Nigeria

41 PUBLICATIONS 163 CITATIONS

[SEE PROFILE](#)



**Olubayo Babatunde**

Tshwane University of Technology

67 PUBLICATIONS 315 CITATIONS

[SEE PROFILE](#)

Some of the authors of this publication are also working on these related projects:



Environment Preservation [View project](#)



Predictive modelling [View project](#)



## Hybrid Power System for a Fuel Station Considering Temperature Coefficient

Oluwaseye Samson Adedoja<sup>1</sup>, Damilola Elizabeth Babatunde<sup>2\*</sup>, Olubayo Moses Babatunde<sup>3</sup>

<sup>1</sup>Centre for Atmospheric Research, National Space Research and Development Agency, Kogi State University, Anyigba, Nigeria, <sup>2</sup>Covenant University, Ota, Ogun, Nigeria, <sup>3</sup>Department of Electrical Electronic Engineering, University of Lagos, Lagos, Nigeria.  
\*Email: [damilola.babatunde@covenantuniversity.edu.ng](mailto:damilola.babatunde@covenantuniversity.edu.ng)

Received: 03 May 2020

Accepted: 01 September 2020

DOI: <https://doi.org/10.32479/ijeeep.9886>

### ABSTRACT

It is crystal clear that appropriate technical sizing has a significant effect on the techno-economic analysis of an off-grid standalone energy system. As a result, this study presents the effect of incorporating the temperature coefficient in the optimal analysis of an off-grid hybrid system using a standard fuel (gas) station in Nigeria as a case study. Comparative analysis with and without the temperature coefficient was performed. The results showed that the inclusion of temperature coefficient leads to extra operation hours of the generator which will result in an increase in fuel consumption and annual operation cost of the diesel generator. Also, the initial cost of the PV/BAT/diesel is relatively higher than the diesel generator but, the generating emission of the hybrid system is lower when compared to the diesel-only which enhances the atmospheric condition of the society.

**Keywords:** Techno-economic Analysis, Hybrid System, Temperature Coefficient, Fuel Consumption

**JEL Classifications:** Q4, Q43

### 1. INTRODUCTION

The increase in population size and rapid urbanization growth across the globe have constrained the public to often depend on the use of fossil fuels as a conventional source of power generation. This, however, does not come without some environmental pollutions with negative consequences on society. Recent studies have attributed the use of fossil fuels as one of the contributors to the alarming climate change and have lately gained significant attention of researchers (Owusu et al., 2016). Over time, in developing countries, and Africa in particular, unreliable power supply is a serious challenge that has overwhelmed the continent, which is neither evenly distributed nor readily available to some inhabitants (Oyedepo, 2012a). More so, depletion of fossil fuels resources calls for promising alternatives and environmentally friendly energy resources. Remarkably, renewable energy sources are freely available in Africa continent, and Nigeria, in particular, considering her positioning on the equator (Oyedepo, 2012b;

Shaaban and Petinrin, 2014). Therefore, exploring and utilizing these renewable energy resources are necessary and, have the tendency of improving energy availability, increasing energy stability and even positioned to mitigate the environmental threat posed by the use fossil fuels and, should be considered.

Despite the numerous advantages and positive prospects associated with renewable energy resources, its major setback remains over-reliance on meteorological conditions, which changes from one location to another and, even, time to time. Interestingly, this can be overawed by integrating some of these resources with conventional systems where the strength of one energy source will complement the weakness of another. For instance, a PV/wind/hydro/diesel/battery hybrid system has a promising trend of providing a reliable energy supply with a cost-effective and less polluted environment. This, however, requires appropriate optimum sizing and components configuration. Consequently, several researchers have considered and, developed hybrid energy systems and established

the fact that it can substantially enhance power system stability. In addition, it is liable to overcome the deficiencies of the stand-alone renewable energy system and, can significantly mitigate the environmental pollutions peculiar to the conventional fossil fuels energy generation. For instance, Asrari et al., 2012 designed a hybrid energy system for a remote community in the Northern part of Iran. The results of their study demonstrated the viability of the system in term of techno-economic and environmental benefits. Güler et al., 2013 investigated and discussed the analysis of four different circumstances of the designed hybrid energy system for a hotel facility using HOMER software. Li et al., 2013 reported the feasibility analysis of a hybrid system developed for family use in Northern, China. Fazelpour et al., 2014 presented the viability of powering the public facility in the Southern part of Iran with the utilization of solar and wind energy. Although, the simulation results exhibited that diesel-battery system was more economical, however, wind-diesel-battery hybrid system attained a significant 14% reduction in emissions of carbon dioxide when compared to the former.

Analysis of economic sustainability of PV/wind/generator hybrid system designed for a rural area of Southern Ghana was reported by Adaramola et al., 2014, considering the economical aspect using HOMER simulation software. Olatomiwa et al., 2015 discussed a PV/diesel/battery hybrid energy system with a focus on the six geo-political regions, in Nigeria. The results of their investigations showed improved fuel consumption and reduced carbon dioxide emissions. The authors in (Amutha and Rajini, 2016) evaluated the house-hold usage, industrial and farmland energy consumption in a typical rural settlement in Southern, India. The authors configured a PV/wind/hydro/battery hybrid energy formulation using HOMER software. The results of their investigation showed the techno-economic benefits and minimized carbon dioxide emissions when compared to the grid supply. Samson et al., 2019 reported the comparison of powering a space research laboratory with diesel and hybrid energy system with latter exhibited a techno-economic and environmental advantages over diesel generator only.

Babatunde et al., 2018 designed a PV/wind/battery system for powering rural health centres in Nigeria. The results showed the techno-economic viability of the hybrid system and its environmental benefits. Application of the hybrid system has also been found useful in the agricultural sector, (Babatunde et al., 2019) and the public lighting system (Babatunde et al., 2019). Although, several studies (Adaramola et al., 2014; Amutha and Rajini, 2016; Asrari et al., 2012; Babatunde et al., 2018; Li et al., 2013; Olatomiwa et al., 2015; Samson et al., 2019) have shown various utilization of hybrid renewable energy resources for both private and public applications. Still, there is no record of its application for gas stations which are predominantly operating on fossil fuels power generation, especially in Nigeria, due to the unreliable power supply peculiar to the developing countries. As a contribution to the studies carried out on the analysis and adoption of renewable energy systems in developing countries, this study presents a techno-economic and environmental viability analysis of powering a gas station with HRES with a specific focus on sub-Sahara. Factors such as temperature coefficient of the panel, ambient

temperature, and configuration of installation affect the yield of a PV installation. Usually, the power output and efficiency of a PV solar panel are dependent on the temperature because an increase in the temperature of a PV solar panel decreases its efficiency and power output. In order to elucidate the need of considering the effects of temperature on the optimal configuration of HRES needed to serve the target load, this study compares the results of sizing with and without temperature coefficient. The remaining part of the paper is prepared as follows: Section 2 presents the case study and methodology approach. Results and discussions are provided in Section 3, while conclusions are highlighted in Section 4.

## 2. CASE STUDY

The selected gas station presented as a case study is located in Maiduguri, in Northern Nigeria. The technical evaluation of the work was based on the assessment of the solar energy potentials of the study area. In Nigeria, in particular, the majority of vehicles are either powered by the premium motor spirit (PMS) or automotive gas oil (AGO) popularly called diesel (Ogunlowo et al., 2015). As a result, gas stations usually operate for about 12 h daily (7:00 am to 7:00 pm [GMT+1]) due to demand from the vehicle owners and operators. Therefore, for effective operations of gas stations, fossil fuels powered generators are mostly employed to curb the incessant power failure. The 12 h operations of this power supply approach has a significant contribution to the growing climate change and constitute a challenge that must be addressed. In order to bridge the identified research gaps, and to minimise its negative consequences on the environment, this study proposes the use of hybrid energy system to power a gas station using, Nigeria, a sub-Saharan Africa. The study employs HOMER software to simulate and derive optimum configuration of components for the case under review.

## 3. METHODOLOGY

The methodology employed for this study is presented in this section.

### 3.1. Technical


The energy demand of the Nigerian National Petroleum Corporation (NNPC) Mega gas station, Maiduguri is used in this study. The demand profile is depicted in Figure 1, which was calculated based on the estimation of various equipment and appliances used daily. Majority of the appliances operates during business hours (7:00 am-7:00 pm), while only the security and refrigerators will work at nights. A sharp drop observed between 8:00 am-9:00 am and 4:00 pm-6:00 pm may be due to low patronage during these hours- some of the fuel nozzles are not working.

### 3.2. Photovoltaic Generator Model

The output from a PV solar panel can be obtained using the mathematical expression given in equation 1 (Bhakta and Mukherjee, 2016; LLC, 2009; Olatomiwa et al., 2016).

$$P_o = P_m \times D_r \left( \frac{G_i}{G_{STC}} \right) \times \left[ 1 + \alpha_p (T_c - T_{c,STC}) \right] \quad (1)$$

**Figure 1:** Load profile of the gas station



$$T_c = T_a + G_i \left( \frac{T_{c,NOCT} - T_{a,NOCT}}{G_r} \right) \quad (2)$$

$P_m$  is the rated output of the module in kW,  $D_r$  is the derating factor of the PV module,  $G_i$  is solar irradiance of the site under consideration rated in kW/m<sup>2</sup>,  $G_{STC}$  is the solar irradiance at standard condition. The PV module temperature coefficient is  $\alpha_p$ , while the temperature of the module and the temperature at standard conditions are  $T_c$ ,  $T_{c,STC}$  respectively.  $T_a$  is the ambient temperature,  $T_{c,NOCT}$  is the rated module temperature with a value ranging between 45°C and 47°C,  $T_{a,NOCT}$  is the ambient temperature at a nominal temperature of 20°C with a solar irradiance  $G_r$  of 0.8 kW/m<sup>2</sup>.

In order to include the temperature coefficient in the design of the energy system, the monthly temperature is important. The average minimum and maximum monthly temperatures for Maiduguri are given in Figure 2. The highest temperature is experienced in the month of April (40°C) while the minimum temperature occurs in January (16°C).

The technical details of the components adapted from (Babatunde et al., 2018) are presented in Table 1.


### 3.3. Battery Bank Capacity Model

Since the solar resource will not be available at night, it is essential that the energy is stored and used at times of insufficiency. In this case, a deep cycle battery is proposed. The rating of the battery bank is obtained using equation 3 (Babatunde et al., 2018). For the case study, the maximum DOD is taken as 40%. This will extend the life span of the battery bank.

$$B_c = \frac{LD \times A_d}{\eta_e \times DoD \times V_s} \quad (3)$$

Where  $LD$ , is the energy demand in kWh,  $A_d$  is the autonomy,  $\eta_e$  is the round-trip efficiency of the battery,  $DoD$  is the depth of discharge and  $V_s$  is the rated voltage of the system.

**Figure 2:** Average minimum and maximum monthly temperatures for Maiduguri



**Table 1: The technical details of the components adapted from (Babatunde et al., 2018)**

PV	
Parameter	Value
Open-circuit voltage	-176.6
Maximum power voltage	54.7
Short-circuit current	6.46
Maximum power rating	327
Maximum power current	5.98
Panel efficiency (%)	20.1
Maximum system voltage (VDC)	600
Cell efficiency (%)	22.55
Power temperature coefficient (°/K)	-0.38
Battery	
Rating	4 V, 600 Ah
Round-trip efficiency (%)	86
Minimum state of charge (%)	40
Diesel generator	
Operational life	15,000 h
Minimum load ratio (%)	30
Generator fuel curve slope (liter/kWh)	0.25

### 3.4. Diesel Generator

In times of insufficiency of the solar resource, diesel generators are used in supporting the load and charging the battery bank. Best practices require that fossil generators are sized so that they can support the peak load (Schmitt et al., 2003). The quantity of fuel usage for a typical diesel generating set is estimated using equation (LLC, 2009).

$$DG_{cr} = (X.P_g) + (Y.P_{ng}) \quad (4)$$

Where  $P_g$ , is the instantaneous power from the diesel generator,  $P_{ng}$ , is the nominal power on the nameplate of the diesel generator, while X (0.2461/kWh) is the slope of the fuel curve slope and Y (0.084151/kWh) is the intercept of the fuel curve.

### 3.5. Economics

In order to evaluate the economic feasibility of the proposed energy system, the total net present cost (TNPC) and the cost of energy are used. This is evaluated using equations 5 and 6, respectively.

TNPC, also known as life cycle cost is the present value of all costs associated with installation, maintenance and replacements of all system components minus the present values of all associated incomes brought in by the system. Cost of energy (COE) is the ratio the average cost in kWh to the total energy served. Details of these can be accessed in (Babatunde et al., 2018).

$$TNPC = \frac{C_{tac}}{CRF(r, L_{proj})} \tag{5}$$

$$COE = \frac{C_{tac}}{E_s} \tag{6}$$

Where  $C_{tac}$  is the total annualized cost,  $CRF()$  is the factor responsible for the recovery of the capital,  $r$  is the interest rate (%) and  $L_{proj}$  is the project lifetime,  $E_s$  is annual load served. The inflation and discount rates are 6% and 10% respectively.

### 3.6. Environmental

Since the hybrid system has an environmental advantage over the diesel generator in term of the greenhouse gas emission reduction. The reduced emission can be deduced to be from the PV source. However, the estimated carbon dioxide is often derived based on the fuel used by the generator. Based on the report of (Jakhrani et al., 2012), various values of carbon dioxide in relation to diesel generator per litre are listed as 3.2, 3.15 and 3.0 kg CO<sub>2</sub>. Therefore, this work adopts an emission value of 2.66 kg of CO<sub>2</sub> per litre (Babatunde et al., 2018). Others include: CO-6.5 g/L,

UH-0.72 g/L, PM-0.49 kg/L, and NO<sub>x</sub> - 58g/L (Babatunde et al., 2019). The emissions are therefore evaluated using:

$$E_x = E_p \cdot x \times TFC_{ann} \tag{7}$$

Where  $E_p \cdot x$  is the emissions factor for pollutant  $x$  and  $TFC_{ann}$  total annual fuel consumption.

## 4. RESULTS AND DISCUSSION

Presented in this section is the results and discussion of the energy system analysis. The optimization results with respect to component sizing, economic implication and emission analysis are depicted in Table 2.

### 4.1. Techno-economic

Table 2 presents the comparison of the PV/DG/BAT system and the diesel-only system. The optimal system that will serve the gas station consists of 125 kW PV panel, 50kW diesel generator, 150 Surrette 4KS25P batteries and 50kW converter with a cycle charging dispatch strategy. For this system, it will require an investment cost of \$197022, while the cost of energy (COE) is \$0.174/kWh. The annual operation cost and total net present cost for the optimal system are \$10152 and \$326793, respectively. When these values are compared with the present mode of electricity generation in the gas station (diesel only generator), there is an increase of more than 900% in terms of the investment cost. The diesel-only generator is far cheaper as compared with the PV/DG/BAT system. An investor may be tempted to pick the

**Table 2: Optimization results**

	Unit	Proposed system without temperature coefficient	Proposed system with temperature coefficient	Diesel Gen. system
		125	130	-
	(kW)	50	50	50
		50	50	0
	(No)	150	150	0
	(%)	84	0.81	0
	(L/yr)	10,988	12,663	80287
	(hr/yr)	736	855	8759
		171,122	155,717	0
Technical		32,178	36,972	181,005
	(kWh/yr)	203,299	192,689	181,005
		146,730	146,730	146,725
		0	0	4
		23663	13,000	34280
	(\$)	197022	202,647	19231
		326793	350,002	652034
	\$/kWh	0.174	0.187	0.348
	(\$/yr)	15412	15,852	1504
Economic		1656	1,808	10649
		1133	1,234	6738
		7362	8,484	32115
		25564	27,379	51007
		10152	11,527	49502
		28936	33,346	211423
		71	82	522
Emission	(kg/yr)	8	9	58
		5	6	39
		58	67	425
		637	734	4657


diesel-only generator due to the huge gap between the investment costs for the two energy systems. However, the TNPC and COE of the diesel-only energy system is approximately double that of the PV/DG/BAT system. Also, the annual operation cost of the diesel-only generator is close to 400% more than that of the proposed hybrid energy system (PV/DG/BAT).

With the inclusion of temperature effects, the size of the PV panel increased from 125kW to 130kW for serving the same load (Table 2). Meanwhile, the quantity of total PV power output considering the inclusion of temperature parameters also


experienced a decrease (from 171122 to 155,717 kWh/yr). Since the PV output with the inclusion of temperature coefficients is lower, the generator attached to the energy system will need to operate an extra 119 h annually to meet the required energy demand of the gas station. This is evident in the monthly energy production, which shows that the monthly contribution of diesel generator increases on a monthly basis when the effect of temperature is included in the design (Figure 3).

Figure 4 shows the Energy production of PV panel and gasoline generator, battery SOC and excess energy for a typical month

**Figure 3:** Monthly energy production (a) without temperature coefficient (b) with temperature coefficient



**Figure 4:** Energy generation, battery SOC and excess energy for a typical month



(January). The state of charge of the battery did not go below 40% (maximum DOD) for any hour of the month. The increase in the operational hours of the generator will consequently increase the diesel fuel consumption as well as the annual operations and maintenance cost of operating the energy system when compared with the system design without the consideration of temperature effect.

As expected, this effectively pushed the cost of energy from 0.174 to 0.187 \$/kWh. Also, the renewable fraction of the energy system reduced from 84% to 81% while the excess energy also reduced by more than 45.06 %. The graphical representation of the annualized costs for the PV/DG/BAT (with and without temperature effects) system and the diesel generator only system is given by Figures 5 and 6, respectively. For the PV/DG/BAT system, the capital cost account for the major part of the annualized cost while for the diesel generator, the money spent on fuel accounts for the major part of the annualized cost.


#### 4.2. Emission

The emission analysis in this study shows that the PV/DG/BAT system will emit the following: 28936 kg of CO<sub>2</sub>, 71 kg of CO, 8kg of UHC, 5 kg of PM, 58 kg of SO<sub>2</sub> and 673 kg of NO<sub>x</sub>. When the temperature effect is included in the system design, the values increases to 33346kg of CO<sub>2</sub>, 82 kg of CO, 9kg of UHC, 6 kg of PM, 67 kg of SO<sub>2</sub> and 734 kg of NO<sub>x</sub>. These values are compared with the diesel-only generator; it is observed that there is a reduction of more than 600% on each pollutant. This will go a long way in reducing the emissions that cause climate change and health-related challenges attributed to emissions.

**Figure 5:** Annualized cost for the PV/DG/BAT energy (a) with temperature coefficient (b) without temperature coefficient



**Figure 6:** Annualized cost for the diesel generator energy system



## 5. CONCLUSIONS

This study has presented the sizing and optimization of a hybrid renewable energy system for a gas station. The study employed the NNPC mega station, Maiduguri, as a case study. The results of the techno-economic-environmental analysis have demonstrated the importance of this study. Also, it is evident that designers of such a system should take into consideration the effect of temperature on the PV panel and its impact on the techno-economic details of an optimal system. This investigation can serve as a planning tool for similar applications in Nigeria and other developing countries. However, government intervention such as the provision of a low-interest loan, subsidized policy on the procurement of renewable energy components is recommended. This will reduce the initial capital cost associated with renewable energy components and will make it more economically viable. It will further encourage investment in large energy projects with a tendency of minimizing carbon dioxide and improves the environmental conditions.

## 6. ACKNOWLEDGMENT

The authors would like to thank Mr. Deji Lawal, who provided us with the data of the station used for this work. The article publication fund received from the Management of Covenant University is acknowledged and appreciated.

## REFERENCES

- Adaramola, M.S., Agelin-Chaab, M., Paul, S.S. (2014), Analysis of hybrid energy systems for application in Southern Ghana. *Energy Conversion and Management*, 88, 284-295.
- Amutha, W.M., Rajini, V. (2016), Cost benefit and technical analysis of rural electrification alternatives in Southern India using HOMER. *Renewable and Sustainable Energy Reviews*, 62, 236-246.
- Asrari, A., Ghasemi, A., Javidi, M.H. (2012), Economic evaluation of hybrid renewable energy systems for rural electrification in Iran: A case study. *Renewable and Sustainable Energy Reviews*, 16(5), 3123-3130.
- Babatunde, M.O., Akinbulire, T.O., Oluseyi, P.O., Emezirinwune, M.U. (2019), Techno-economic viability of off-grid standalone PV-powered LED street lighting system in Lagos, Nigeria. *African Journal of Science, Technology, Innovation and Development*, 11(7), 1-13.
- Babatunde, O., Akinyele, D., Akinbulire, T., Oluseyi, P. (2018), Evaluation of a grid-independent solar photovoltaic system for primary health centres (PHCs) in developing countries. *Renewable Energy Focus*, 24, 16-27.
- Babatunde, O.M., Denwigwe, I.H., Adedoja, O.S., Babatunde, D.E., Gbadamosi, S.L. (2019), Harnessing renewable energy for sustainable agricultural applications. *International Journal of Energy Economics and Policy*, 9(5), 308-315.
- Babatunde, O.M., Munda, J.L., Hamam, Y. (2019), Selection of a hybrid renewable energy systems for a low-income household. *Sustainability*, 11(16), 4282.
- Bhakta, S., Mukherjee, V. (2016), Solar potential assessment and performance indices analysis of photovoltaic generator for isolated Lakshadweep Island of India. *Sustainable Energy Technologies and Assessments*, 17, 1-10.
- Fazelpour, F., Soltani, N., Rosen, M.A. (2014), Feasibility of satisfying

- electrical energy needs with hybrid systems for a medium-size hotel on Kish Island, Iran. *Energy*, 73, 856-865.
- Güler, Ö., Akdag, S.A., Dinçsoy, M.E. (2013), Feasibility analysis of medium-sized hotel's electrical energy consumption with hybrid systems. *Sustainable Cities and Society*, 9, 15-22.
- Jakhrani, A.Q., Rigit, A.R.H., Othman, A.K., Samo, S.R., Kamboh, S.A. (2012), Estimation of carbon footprints from diesel generator emissions. *2012 International Conference on Green and Ubiquitous Technology*, 1, 78-81.
- Li, C., Ge, X., Zheng, Y., Xu, C., Ren, Y., Song, C., Yang, C. (2013), Techno-economic feasibility study of autonomous hybrid wind/PV/battery power system for a household in Urumqi, China. *Energy*, 55, 263-272.
- LLC. (2009), Hybrid Optimization Model for Electric Renewables. Available from: <http://www.homerenergy.com>. [Last accessed on 2019 Oct 30].
- Ogunlowo, O.O., Bristow, A.L., Sohail, M. (2015), Developing compressed natural gas as an automotive fuel in Nigeria: Lessons from international markets. *Energy Policy*, 76, 7-17.
- Olatomiwa, L., Mekhilef, S., Huda, A.S.N., Ohunakin, O.S. (2015), Economic evaluation of hybrid energy systems for rural electrification in six geo-political zones of Nigeria. *Renewable Energy*, 83, 435-446.
- Olatomiwa, L., Mekhilef, S., Ismail, M.S., Moghavvemi, M. (2016), Energy management strategies in hybrid renewable energy systems: A review. *Renewable and Sustainable Energy Reviews*, 62, 821-835.
- Owusu, P.A., Asumadu-Sarkodie, S. (2016), A review of renewable energy sources, sustainability issues and climate change mitigation. *Cogent Engineering*, 3(1), 1167990.
- Oyedepo, S.O. (2012a), Energy and sustainable development in Nigeria: The way forward. *Energy, Sustainability and Society*, 2(1), 15.
- Oyedepo, S.O. (2012b), On energy for sustainable development in Nigeria. *Renewable and Sustainable Energy Reviews*, 16(5), 2583-2598.
- Samson, A.O., Babatunde, O.M., Denwigwe, I.H. (2019), Powering a space environment research laboratory (SERL): Hybrid renewable energy system or diesel system? *Energy Engineering*, 116(2), 41-64.
- Schmitt, A., Huard, G., Jacquin, P. (2003), Recommendations for Small Renewable Energy and Hybrid Systems for Rural Electrification. Kassel, Germany: 2<sup>nd</sup> European PV-Hybrid and Mini-Grid Conference. p253-258.
- Shaaban, M., Petinrin, J.O. (2014), Renewable energy potentials in Nigeria: Meeting rural energy needs. *Renewable and Sustainable Energy Reviews*, 29, 72-84.