PAPER • OPEN ACCESS

Design and implementation of a single phase to three phase rotary converter

To cite this article: J. O. Olowoleni et al 2021 J. Phys.: Conf. Ser. 1734 012029

View the article online for updates and enhancements.

You may also like

- A novel three-phase excitation piezoelectric motor for macro-micro actuation: integration design, systematic modeling, and experimental evaluation Jianmin Qiu, Ying Yang, Jiamei Jin et al.
- Experimental validation of solar-panel-tied three-port switched-inductor-based dualboost DC-DC-converter-fed three-phase micro-inverter
 S Kamalathiyagarajan and S Chitra Selvi
- Phase fraction measurement of oil-gas-water three-phase flow with stratified gas by ultrasound technique Qian Su, Xiangtian Deng, Zhenxing Liu et al.

1734 (2021) 012029

doi:10.1088/1742-6596/1734/1/012029

Design and implementation of a single phase to three phase rotary converter

¹Olowoleni J.O, ²Awosope C.O.A, ³Adoghe A.U., ⁴Oguntosin V., ⁵Okupevi E.S

^{1,2,3,4,5}Department of Electrical and Information Engineering, School of Engineering, Covenant University Ota, Nigeria

Contact Email: joseph.olowoleni@covenantuniversity.edu.ng

Abstract. Epileptic power supply, scarcity of fuel, and the ever increasing demand for power supply have given rise to the development of several off-grid and on-grid power alternatives. A single phase to three phase rotary phase converter is a machine that can generate three phase power supply from an existing single phase source. This is a cheap means of generating three phase power especially in some residential environments where access to three phase power is limited. Some home equipment such as air conditioners and refrigerators run on three phase power also workshop owners and technicians have need to operate three phase machinery which may include table saw, drilling machine, lathe machine, and any machinery that runs on three phase power.

1. Introduction

Several types of converters have been implemented, In November 2012, Shivanagouda. Patil and Aspalli [1], proposed and implemented the principle of operation of a three phase induction motor from a single phase supply. The system made use of a half bridge rectifier along with split capacitors combination, half bridge inverter and triac combination and a 16 bit High efficiency digital signal controller.

The single phase to three phase rotary converter is quite different from all other types of converters. This is because it makes use of an automotive alternator to generate a three wire alternating voltage [2], [4].

2. Methodology

The single phase to three phase rotary converter consists of a single phase motor and an automotive alternator, the single phase electric motor is used to drive the automotive alternator [3]. The motor is powered from a 220-230V single phase supply, it is mechanically coupled to the automotive alternator using a pulley drive system.

2.1. Alternator operation

It is a three-phase generator with an in-built rectifier circuit comprising of six diodes circuits to convert the alternating current output from the stator of the alternator to Direct current [5]. As the sheave or pulley is been rotated by a belt attached to the crankshaft of the automobile engine, across a stationary set of three-phase windings, there are magnet spins, i.e. the stator, which is mainly connected in a star configuration [6]. An electromagnet, and not a permanent magnet, is a spinning or


Published under licence by IOP Publishing Ltd

Content from this work may be used under the terms of the Creative Commons Attribution 3.0 licence. Any further distribution of this work must maintain attribution to the author(s) and the title of the work, journal citation and DOI.

1734 (2021) 012029 doi:10.1088/1742-6596/1734/1/012029

rotating magnet. Alternators are designed so that their magnetic field intensity can be regulated, and the output voltage can even be autonomously controlled by rotor velocity[7]. The battery power energizes the rotor magnet coil, which is called the field coil, in order to take a large amount of electrical power input to the alternator rotor to produce an excitation that will enable it to generate adequate output power.

For the purpose of this project the rectifier circuit has to be removed and the three phase alternating current output wires initially connected to the rectifier circuit is rewired out of the stator. Also a wire is center tapped between the stator coils to form the neutral wire while the field wires remain in place. A 12/240v 2AM transformer is used to step up each leg of the alternator output. A 12.75AH battery is used to excite the rotor coil [8].



3. Construction

To drive the alternator with a single phase motor, a pulley had to be constructed on the shaft of the single phase motor. The alternator comes with an already fitted 70mm diameter pulley and it requires a speed of about 2500 rpm to generate its rated voltage and the motor speed is 1300 rpm, so to increase the speed on the alternator pulley a larger pulley was constructed on the motor. The size of the pulley was determined using velocity ratio.

The ratio was worked out mathematically thus:

Velocity Ratio:

$$VR = \frac{speed\ of\ driven(rpm)}{speed\ of\ driver\ (rpm)} = \frac{N2}{N1} = \frac{d1}{d2} = \frac{2500}{1300} = \frac{25}{13}$$

Therefore d1:d2 = 2:1 approximately

Where:

N2 – required speed of alternator

N1 – speed of the motor at full load

d1 – diameter of driver pulley (single phase motor)

d2 - diameter of driven pulley (alternator)

3.1. Design Calculation

3.1.1. Motor Input Power.

$$P1 = \frac{P2}{n\cos\varphi}$$

1734 (2021) 012029

doi:10.1088/1742-6596/1734/1/012029

$$= 0.75 \times 10^3 / 0.95 \times 0.85 = 0.93$$
KW

3.1.2. The Belt's Velocity.

The belt's velocity may be expressed as:

$$v = \frac{\pi d_m n_m}{12}$$

Where

$$v = velocity of belt (rpm)$$

$$n_m = speed of motor (rpm)$$

 $d_m = diameter of motor pulley (in)$

$$v = 3.14 \times 5.51 \times 1380/12 = 1989 \, rpm \cong 2000 \, rpm$$

3.1.3. Torque Developed.

$$T = \frac{63025 P_{hp}}{n}$$

Where

P = output power(hp)

n = speed of rotation(rpm)

T = Torque developed (lb in)

 $T = 63025 \times 1/1380 = 46 lb in = 5.2 Nm$

3.1.4. Horsepower Transferred.

If the belt's tension and velocity are known, the horsepower transferred can be calculated as

$$P_{hp} = \frac{F_b V_b}{33000}$$

Where:

$$P_{hn} = power(hp)$$

$$F_b = belt tension (lb_f)$$

$$v_b = velocity of belt (ft/min)$$

If torque and the revolution per minute of the motor are known, then, the horsepower transferred can be calculated as:

$$P_{hp} = \frac{Tn}{5252}$$

Where:

$$P_{hp} = power(hp)$$

$$T = torque(ft lb_f)$$

n = speed(rpm)

$$3.8 \times 1380/5252 = 0.99 \cong 1HP$$

3.1.5. Alternator Pulley Speed.

1734 (2021) 012029 doi:10.1088/1742-6596/1734/1/012029

$$N_d = \frac{D_m \times N_m}{D_a}$$

Where:

 $N_a = alternator pulley speed(rpm)$

 $D_m = diameter of motor pulley (in.)$

 $N_m = motor\ pulley\ speed(rpm)$

 $D_a = diameter of alternator pulley(in.)$

$$N_d = \frac{5.51 \times 1380}{2.76} = 2755 \, rpm$$

3.1.6. The Speed's Ratio.

This can be calculated as:

$$SR = \frac{n_f}{n_s}$$

Where:

 $SR = speed \ ratio$

 n_f = speed of fastest machine

 n_s = speed of slowest machine

$$\frac{2755}{1380} = 1.996$$

4. Conclusion

The output voltage of the alternator was for phase voltages 25V, 23V, 15V and line voltages 43V, 39V, 26V. This imbalance in the output voltages is due to the way the alternator was wound. Further advancement and improvements on this research work would improve its capacity. These improvements would be to balance the output of the transformer, and also to step up this output voltage using transformers. This project has shown the possibility of generating three phase power cheaply using an automotive alternator. Also it has helped in the understanding of how alternators work and they can be used as converters.

I recommend for any future implementation of any project of this kind, that speed and torque should be put into consideration as they are the determinant factors of the output or capacity of the system. Also it should be noted that the power rating of the loads must not be as high as that of the alternator and the motor used

Acknowledgements

The authors wish to appreciate the Center for Research, Innovation, and Discovery (CU-CRID) of Covenant University, Ota, Nigeria, for partly funding of this research.

References

- [1] Shivanagouda.B.Patil, M.S Aspalli, Operating three phase Induction Motor Connected to Single Phase Supply. International Journal of emerging technology and advanced engineering.
- [2] Nesbitt.J et al, A novel single phase to three phase converter, Applied power electronics conference 1991, IEEE Explore digital library

1734 (2021) 012029 doi:10.1088/1742-6596/1734/1/012029

- [3] Radha Krishna, Amar Kiran, Modeling of Single phase To Three Phase Drive system Using Two Parallel Single Phase Rectifiers, International journal of modern engineering Research (IJMER).
- [4] K.G Mohammed, A.Q Ramli, A new design of six phase rotary converter electric machine. International journal of integrated engineering.
- [5] Shi Long Chen. One phase to three phase converter based on thyristor controlled reactor. IEEE Explore digital library.
- [6] A textbook of electrical technology. 3rd edition B.L. Theraja.
- [7] Electrical machines, drives and power systems, 5th edition. Theodore Wildi
- [8] Electrical machines technology and electrical power systems. TQ Education and training limited